

## 万达热电万达热电1#1-3号75t/h循环流化床

企业名称	排口名称	时间	二氧化硫			氮氧化物		
			实测浓度 (mg/M <sup>3</sup> )	折算浓度 (mg/M <sup>3</sup> )	排放量 (kg)	实测浓度 (mg/M <sup>3</sup> )	折算浓度 (mg/M <sup>3</sup> )	排放量 (kg)
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-01 00	22.3	24.4	0.125	35.9	39.2	0.201
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-01 01	17.3	18.8	0.097	34.7	37.9	0.194
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-01 02	14.4	16.2	0.078	36.6	42.3	0.201
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-01 03	15.1	18.7	0.085	32.8	40.7	0.183
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-01 04	16.6	20.1	0.092	34	41.3	0.188
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-01 05	19.5	22.3	0.109	34	39.2	0.19
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-01 06	21.3	24	0.119	31.6	35.8	0.177
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-01 07	19.9	22.8	0.111	33.9	39	0.19
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-01 08	15.2	17	0.086	38.1	42.5	0.214
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-01 09	11.2	13.3	0.062	37.4	44	0.207
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-01 10	13.7	16.5	0.077	32.9	40	0.186
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-01 11	13.6	16.6	0.077	34.6	42.4	0.196
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-01 12	15.1	17.8	0.086	35.2	41.5	0.2
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-01 13	16.2	18.9	0.092	34.9	41	0.198
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-01 14	3.64	4.32	0.021	33.7	39.9	0.192
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-01 15	19.3	22.4	0.108	33.1	38.8	0.185

万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-01 16	20.6	24.4	0.117	32.3	38.4	0.183
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-01 17	16.9	19.8	0.096	30.7	36	0.174
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-01 18	18.3	21.2	0.101	33.3	38.6	0.184
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-01 19	14.1	16.2	0.079	32.8	37.7	0.183
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-01 20	14.6	16.8	0.081	32.2	37.1	0.18
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-01 21	11.7	13.8	0.065	32.8	38.7	0.183
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-01 22	5.82	7.03	0.032	31	37.6	0.174
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-01 23	6.82	8.4	0.037	34	41.6	0.185
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-02 00	7.12	8.78	0.041	32.7	40.4	0.184
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-02 01	10.7	13.2	0.06	31.8	39	0.179
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-02 02	13.9	17.3	0.079	32.7	40.6	0.184
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-02 03	12.7	15.3	0.072	30.8	37.3	0.174
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-02 04	12.7	16.1	0.072	32.6	41.4	0.185
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-02 05	15.4	18.8	0.087	30.7	37.8	0.174
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-02 06	16.8	20.1	0.096	30.6	36.6	0.173
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-02 07	15.4	17.9	0.086	30.6	35.5	0.172
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-02 08	19.5	22.2	0.11	38.5	44	0.216
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-02 09	17.9	19.6	0.1	38.1	42	0.213
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-02 10	13.7	15.6	0.078	39.3	44.7	0.222

万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-02 11	6.79	7.7	0.039	35.8	40.4	0.203
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-02 12	15.7	17.9	0.089	37	42.2	0.209
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-02 13	11.9	13.5	0.067	37.3	42.5	0.211
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-02 14	10.7	12	0.059	37.4	42	0.208
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-02 15	14.7	16.3	0.083	35.7	39.6	0.202
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-02 16	6.57	7.49	0.037	33.8	38.8	0.19
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-02 17	13.2	15.3	0.074	34.9	40.5	0.198
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-02 18	18	21.2	0.102	34.4	40.6	0.194
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-02 19	19.5	23.3	0.11	34.4	41.2	0.194
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-02 20	24	27.8	0.136	33.1	38.4	0.186
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-02 21	22.1	25.4	0.122	35.1	40.6	0.193
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-02 22	17.3	20.5	0.095	32.1	38.1	0.177
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-02 23	21.2	24.7	0.118	31.4	36.7	0.175
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-03 00	17.3	20.1	0.096	31.6	36.6	0.175
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-03 01	6.37	7.58	0.035	33.9	39.9	0.185
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-03 02	19.9	23.6	0.11	33.5	39.7	0.186
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-03 03	20.7	24.4	0.115	33.2	39	0.183
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-03 04	19.7	23	0.109	33.6	39.4	0.186
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-03 05	20.2	24.3	0.112	32.7	39.4	0.182

万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-03 06	21.4	25.4	0.119	34.6	41.5	0.193
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-03 07	21.3	25.6	0.118	33.6	40.5	0.188
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-03 08	26.2	30.5	0.147	33.8	39.5	0.19
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-03 09	24.1	29.1	0.136	36.3	43.7	0.205
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-03 10	19.9	24.2	0.112	31.3	38.1	0.176
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-03 11	16.8	20.3	0.093	35.1	42.4	0.194
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-03 12	17.8	20.8	0.1	34.8	40.7	0.196
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-03 13	21.5	25.4	0.122	37.3	44	0.211
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-03 14	27	31.5	0.153	34.8	40.6	0.198
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-03 15	6.99	8.32	0.04	34.7	40.6	0.198
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-03 16	14.6	17	0.081	31.7	37	0.176
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-03 17	11.2	13.4	0.063	32.1	37.9	0.18
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-03 18	9.28	10.7	0.052	32.8	38.2	0.182
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-03 19	13.9	15.8	0.077	32.6	38.1	0.181
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-03 20	18.2	20.8	0.1	34.3	39.3	0.189
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-03 21	17.6	20.5	0.097	35.3	41.1	0.194
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-03 22	10.5	12.5	0.059	33.4	39.6	0.185
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-03 23	16.3	19.2	0.089	34.4	40.8	0.187
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-04 00	21.5	25.7	0.119	33.1	39.6	0.184

万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-04 01	22.5	26.7	0.125	33.9	40.2	0.188
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-04 02	24.4	29.3	0.134	33.6	40.3	0.186
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-04 03	18	21.6	0.1	34	40.7	0.187
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-04 04	18.2	21.8	0.1	35.8	42.8	0.197
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-04 05	20.9	25.3	0.115	33.1	40.1	0.183
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-04 06	21.6	25.7	0.119	32	38.4	0.177
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-04 07	24.9	29.5	0.138	33.6	39.8	0.185
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-04 08	20.7	23.2	0.114	32	35.9	0.176
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-04 09	20.3	22.5	0.111	35.6	39.5	0.194
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-04 10	22	24.5	0.118	34.9	38.9	0.188
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-04 11	22.9	25.4	0.126	35.5	39.3	0.195
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-04 12	12.3	13.9	0.068	35.3	39.7	0.194
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-04 13	22.1	24.6	0.121	34.3	38.2	0.188
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-04 14	18.6	20.9	0.102	33	37.4	0.181
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-04 15	23.1	26.2	0.124	32.1	36.4	0.172
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-04 16	19.2	21.5	0.104	35.3	39.6	0.191
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-04 17	22.4	25.4	0.122	37.2	42.2	0.203
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-04 18	11.7	13.5	0.064	35.5	40.7	0.193
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-04 19	7.2	8.15	0.039	36.9	41.8	0.201

万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-04 20	14.5	16.5	0.079	38.2	43.5	0.208
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-04 21	4.74	5.5	0.026	35.6	41	0.196
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-04 22	6.39	8.33	0.036	30.9	39.9	0.172
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-04 23	25.9	33.6	0.145	31.6	40.9	0.176
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-05 00	6.35	8.1	0.035	36.8	46.9	0.205
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-05 01	13.6	16	0.076	39.4	47.4	0.221
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-05 02	12.6	14.6	0.07	28.5	33.1	0.158
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-05 03	12.9	15.1	0.071	32.7	38	0.18
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-05 04	13.3	15.9	0.074	33.9	40.1	0.187
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-05 05	17	20.2	0.094	32	38	0.176
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-05 06	15.6	18.7	0.087	34.9	42	0.194
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-05 07	13.1	15.5	0.073	32.8	39	0.182
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-05 08	19.2	22.1	0.107	29.3	33.7	0.162
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-05 09	15.6	17.9	0.087	35.5	40.6	0.197
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-05 10	11.6	13.5	0.064	35.8	41.9	0.198
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-05 11	17.3	20.3	0.096	37.2	43.1	0.206
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-05 12	12.5	14.5	0.069	34.9	40.3	0.194
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-05 13	22.1	26.1	0.124	37.9	44.7	0.212
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-05 14	19.1	22.4	0.108	36.7	43.1	0.208

万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-05 15	14.3	17.1	0.082	35.5	42.7	0.203
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-05 16	17.8	20.9	0.102	33.2	39.2	0.19
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-05 17	21.1	24.9	0.121	27.8	32.9	0.159
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-05 18	14.2	16.5	0.08	33.2	38.5	0.188
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-05 19	16.7	19	0.094	37	42	0.208
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-05 20	9.91	11.3	0.055	36.7	42.1	0.206
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-05 21	20.9	23.6	0.116	37.9	42.9	0.212
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-05 22	16.2	19	0.091	38.4	45.1	0.215
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-05 23	17.9	21.3	0.1	33.9	40.4	0.19
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-06 00	16.4	19.4	0.091	34.6	41	0.191
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-06 01	19	22	0.107	33.9	39.2	0.191
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-06 02	16.8	19.4	0.094	35.7	41.2	0.2
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-06 03	14.9	17.4	0.084	35.6	41.6	0.2
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-06 04	16.2	19.3	0.091	35.5	42.5	0.2
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-06 05	16.9	20.4	0.096	36.7	44.4	0.208
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-06 06	17	20	0.096	34.3	40.3	0.194
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-06 07	12.1	14.2	0.068	32.8	38.3	0.185
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-06 08	14.6	17	0.082	31.7	36.8	0.178
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-06 09	19.3	22.4	0.108	32.6	37.9	0.183

万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-06 10	20.9	23.9	0.118	31.8	36.4	0.179
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-06 11	17.5	20.2	0.098	33.6	39	0.19
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-06 12	14.5	17.2	0.083	34.4	40.8	0.195
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-06 13	17	20.1	0.096	33.3	39.4	0.189
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-06 14	20.6	25	0.116	33.6	40.8	0.191
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-06 15	19.4	23.1	0.11	34.1	40.7	0.194
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-06 16	19.6	23.7	0.111	32.4	39.3	0.185
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-06 17	17.2	20.9	0.098	31.1	37.7	0.177
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-06 18	21.8	26.1	0.122	32.2	38.7	0.18
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-06 19	19.8	23.4	0.112	31.7	37.6	0.18
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-06 20	16.8	20.1	0.095	33.3	39.9	0.188
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-06 21	17.7	20.8	0.1	32.4	38.3	0.183
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-06 22	15.9	18.8	0.088	31.6	37.4	0.175
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-06 23	18.9	22.9	0.106	33.1	40.3	0.186
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-07 00	21.2	25.5	0.12	33.2	40	0.187
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-07 01	21.3	25.4	0.12	33.3	39.9	0.188
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-07 02	20.4	24	0.114	33.1	38.9	0.186
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-07 03	17.2	20.2	0.096	35.2	41.4	0.198
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-07 04	16.3	19	0.091	34	39.6	0.188



万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-07 05	14.8	17.4	0.084	34.9	41.2	0.197
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-07 06	21.9	26	0.123	34.4	40.7	0.192
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-07 07	20.2	23.9	0.114	34.2	40.3	0.192
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-07 08	16.8	19.8	0.095	34.5	40.6	0.194
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-07 09	20.1	23.6	0.114	33.2	39	0.188
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-07 10	17.2	20	0.096	34.1	39.8	0.191
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-07 11	15.3	18.1	0.087	34.3	40.5	0.194
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-07 12	15.3	17.8	0.086	33.3	39	0.187
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-07 13	14.6	16.6	0.082	32	36.5	0.18
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-07 14	13.6	15.8	0.077	35.2	40.8	0.199
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-07 15	17	19.9	0.088	34.6	40.5	0.18
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-07 16	15.7	18	2.3	35.1	40.4	5.08
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-07 17	16.7	19.9	3.56	36.4	43.2	7.74
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-07 18	16.6	19.5	3.67	35.8	42	7.93
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-07 19	16.6	19.4	3.84	35.3	41.3	8.16
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-07 20	14.8	16.7	3.55	35	39.5	8.41
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-07 21	13.3	15	3.15	39.2	44.5	9.34
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-07 22	14	16.1	3.42	37.5	43	9.14
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-07 23	13.5	15.7	3.25	39.3	45.6	9.41

万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-08 00	12.7	14.7	3.89	35.3	41.1	10.8
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-08 01	14.4	17	5.39	37.8	44.5	14.2
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-08 02	15.1	17.9	6.1	36.4	43.2	14.6
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-08 03	23.9	28.3	8.8	37.2	44.2	13.7
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-08 04	25	29.7	10.8	35	41.5	15.3
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-08 05	20.8	24.5	7.94	35.1	41.3	13.3
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-08 06	22.8	26.8	8.34	35	41.1	12.8
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-08 07	25.2	29.6	10.3	35.4	41.5	14.4
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-08 08	25.2	29.5	11.3	33.7	39.4	15.1
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-08 09	24.5	29	11.7	32.7	38.6	15.5
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-08 10	25.8	30.3	12.7	33.1	38.9	16.3
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-08 11	24.5	27.4	12.1	33.3	37.2	16.4
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-08 12	22.6	25.7	11.6	34.2	38.9	17.5
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-08 13	21.7	24.7	11.5	34.2	39.1	18
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-08 14	21.6	24.5	11.2	32.7	37.1	16.9
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-08 15	27	30.3	14.5	34.8	39.3	18.7
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-08 16	26.4	29.3	14.2	32.2	35.8	17.3
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-08 17	30.2	33.7	14.8	34	38	16.5
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-08 18	27.7	32.3	12.1	34.7	40.6	14.8

万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-08 19	29.8	33.4	10.7	28.9	32.6	10.2
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-08 20	22.5	25.4	7.94	31.4	35.4	10.9
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-08 21	23.5	27	4.94	32.5	37.3	6.76
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-08 22	23.5	27.3	2.03	32.5	37.8	2.75
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-08 23	20.7	24.3	1.78	33.5	39.3	2.85
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-09 00	17	20.2	3.13	32.8	39	6.13
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-09 01	20.6	23.5	4.4	30.4	34.7	6.6
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-09 02	20.5	23.4	6.07	32.5	37	9.57
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-09 03	23.8	27.5	7.63	34.4	39.9	10.9
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-09 04	21.3	24.9	6.3	34.7	40.7	10.3
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-09 05	19.4	22.5	5.32	35	40.6	9.61
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-09 06	20.9	23.8	6.44	30.9	35.3	9.5
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-09 07	22.6	25.7	8.42	30.2	34.3	11.2
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-09 08	24.9	28.1	11.1	32.9	37.1	14.7
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-09 09	25.8	28.6	10.4	33.6	37.3	13.6
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-09 10	27.3	30.3	10.6	33.9	37.7	13.1
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-09 11	24.1	26.7	10.8	31.7	35.1	14.3
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-09 12	24.7	27.6	12.1	34.2	38.3	16.7
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-09 13	24.8	27.5	12.2	34	37.7	16.7

万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-09 14	22.1	24.5	11.7	34.6	38.4	18.3
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-09 15	21.9	24.7	12	31.7	35.8	17.5
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-09 16	23.8	26.7	13.3	29.4	32.9	16.4
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-09 17	20.1	22.8	11.1	32.4	36.7	17.8
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-09 18	24	27.9	13.3	34	39.7	18.7
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-09 19	22.8	25.8	11	30.3	34.4	14.6
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-09 20	22	24.4	9.75	30.6	34.1	13.5
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-09 21	24.2	26.8	8.97	32.5	36.1	12.2
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-09 22	20.7	23.2	7.95	33.5	37.7	12.9
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-09 23	20.1	22.4	7.98	34.6	38.5	13.7
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-10 00	25.1	27.3	10.2	34.7	37.7	14.1
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-10 01	21.6	23.2	9.19	36.4	39.1	15.5
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-10 02	21.7	23.7	9.63	37.2	40.7	16.5
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-10 03	19.9	22.2	8.32	36.9	41.2	15.5
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-10 04	23.2	25.3	10	36.8	40.3	15.9
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-10 05	21	23.3	9.23	36.3	40.4	16
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-10 06	21.9	24.1	7.58	36.7	40.5	12.8
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-10 07	22.3	24.5	3.62	37.8	41.4	6.48
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-10 08	25.6	28.7	5.01	39.3	44.2	7.97

万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-10 09	26.1	29.5	11.6	37	41.8	16.1
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-10 10	24.9	28.1	11.5	37.4	42.2	17.3
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-10 11	20	22.6	9.75	39.7	44.9	19.3
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-10 12	20.6	23.6	10.8	37.1	42.5	19.6
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-10 13	22	25.1	12.4	37.1	42.4	20.9
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-10 14	23	26.3	12	35	39.9	18.3
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-10 15	22.6	25.7	11.5	36.3	41.2	18.5
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-10 16	24.3	27.4	12.5	34	38.4	17.4
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-10 17	20.7	23.6	11.2	34.9	39.8	19.1
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-10 18	24.5	28.1	12	35.7	41.1	17.5
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-10 19	17.4	19.6	7.98	35.3	39.8	16.1
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-10 20	20.1	22.7	9.08	36.2	40.9	16.4
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-10 21	21.4	24.8	10.3	34	39.4	16.4
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-10 22	22.6	26.7	10.3	35.8	42.3	16.4
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-10 23	15.1	17.8	6.88	36.2	42.6	16.5
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-11 00	22.8	26.2	7.98	30.8	35.4	10.9
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-11 01	20.5	23.4	7.24	32.4	37	11.4
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-11 02	20.5	23.1	7.19	32	36.1	11.3
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-11 03	19.9	22.2	7.28	32.2	35.8	11.8

万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-11 04	17.9	20.7	7.01	34.4	39.7	13.5
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-11 05	17.4	20.2	6.57	33.1	38.6	12.5
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-11 06	20.4	23.5	8.3	33.7	38.9	13.7
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-11 07	22.5	26	10.1	35.1	40.6	15.6
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-11 08	19.6	22.3	9.54	35	40	17
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-11 09	22	24.1	10.6	37.4	41	18.1
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-11 10	18	20.2	9.37	39.9	44.9	20.9
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-11 11	21.3	23.8	11.8	37.6	41.9	20.8
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-11 12	20	22.6	11.1	38.4	43.4	21.4
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-11 13	23.3	25.8	13.4	36.4	40.3	20.9
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-11 14	21.9	24.5	12.3	36.5	40.9	20.4
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-11 15	23.4	26.5	14	36.2	41	21.7
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-11 16	24.1	27.6	14.8	33.8	38.8	20.8
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-11 17	26.8	30.4	15.4	33.2	38	19
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-11 18	22.1	25.3	12	32.7	37.3	17.7
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-11 19	25	28	14.3	34.5	38.7	19.8
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-11 20	20.7	23	11.4	34.9	38.9	19.1
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-11 21	21.9	25	11.1	35.7	40.8	18.1
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-11 22	25.7	30.1	13.1	34.4	40.5	17.6

万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-11 23	19.4	22.3	9.29	33.3	38.5	15.9
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-12 00	19	22.4	9.38	31.3	36.7	15.4
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-12 01	20.6	23.7	10.2	33.8	39	16.7
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-12 02	18.9	21.6	8.88	32.7	37.3	15.3
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-12 03	19.1	22	8.78	32.8	37.8	15.1
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-12 04	21.2	24.7	9.68	34.5	40.4	15.8
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-12 05	18.7	21.5	8.09	34.8	40.1	15
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-12 06	24.4	27.9	12.2	35.6	40.7	17.9
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-12 07	24.5	28.3	12.2	37.3	43	18.6
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-12 08	19	21.7	10.3	33.5	38.4	18
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-12 09	15	16.6	7.27	33.9	37.7	16.4
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-12 10	12	13.5	6.22	36.1	40.6	18.8
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-12 11	16.4	18.1	8.94	34.8	38.6	18.9
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-12 12	15.5	17.6	8.48	36.9	42	20.1
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-12 13	18.8	21	10.9	35.9	40.3	20.6
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-12 14	26	28.8	14.1	36	40.1	19.3
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-12 15	25.3	28.1	12.4	36.4	40.3	18
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-12 16	22.1	25	12.2	36.7	41.8	20.3
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-12 17	18	21	9.74	35.9	42	19.5

万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-12 18	15.9	19	7.41	33.9	40.7	16.6
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-12 19	23.1	26.7	10.6	33.5	38.8	15.4
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-12 20	18.8	21.4	8.8	36.6	41.7	17
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-12 21	21.3	23.7	9.8	38.3	42.7	17.6
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-12 22	20.2	23.2	9.46	39.7	45.6	18.5
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-12 23	21.3	24.2	8.91	35	39.7	14.6
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-13 00	17.9	20.4	7.24	33.5	38.4	13.5
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-13 01	19.3	21.6	8.19	33.7	37.8	14.3
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-13 02	21.5	24.5	9.43	36.9	42	16.2
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-13 03	22.6	25.6	8.95	35.1	39.8	13.9
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-13 04	21.7	24.6	8.96	33.1	37.6	13.7
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-13 05	22.2	25.2	10.4	35.6	40.5	16.8
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-13 06	10.4	12.2	4.4	35.9	42.5	17.3
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-13 07	13.1	15.6	6.99	33.7	39.9	18.7
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-13 08	19.1	22.3	8.49	34	39.6	15.4
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-13 09	16.9	18.7	7.69	29.9	33.3	13.5
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-13 10	16.8	19	8.21	34.6	38.9	16.8
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-13 11	20.4	23.2	10.8	33.7	38.4	17.8
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-13 12	18.8	21.6	9.99	32	36.8	17



万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-13 13	15.8	18	10	34.5	39.4	22
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-13 14	21.9	25.6	13.4	34.5	40.3	21
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-13 15	24	27.3	10.2	32.9	37.3	13.9
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-13 16	21.5	24.8	10.2	36.7	42.6	17.4
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-13 17	22.2	25.5	9.66	36.2	41.7	15.7
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-13 18	20	23.3	7.19	34.7	40.6	12.4
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-13 19	21.6	24.3	7.24	33.7	38	11.3
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-13 20	21.6	24.4	7.63	39	44.2	13.4
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-13 21	19.8	22.4	5.9	36.3	41.2	10.7
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-13 22	24	27.3	6.32	36	41.1	9.51
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-13 23	21.8	24.8	7.95	36	41	13.4
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-14 00	13.3	15.3	4.32	33.9	38.9	10.8
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-14 01	9.57	11	2.83	35.1	39.9	10.7
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-14 02	18.2	20.5	5	35	39.7	9.75
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-14 03	16.8	18.8	3.9	37	41.8	8.63
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-14 04	18.9	21.8	0.836	34.6	40	1.66
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-14 05	21.2	24.3	2.59	33.8	38.8	4.26
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-14 06	17.5	20.5	4.34	31.1	36.6	7.94
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-14 07	17.4	19.9	7.24	33	38	13.7

万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-14 08	16.4	18.1	7.08	32.1	36.3	13.5
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-14 09	22	24.3	9.3	33	36.6	13.9
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-14 10	16.1	17.8	6.32	31.9	35.5	12.7
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-14 11	17.7	19.5	8.47	30.8	34.1	14.8
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-14 12	17.5	19.2	8.05	30.7	34	14.3
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-14 13	15.4	17.4	7.26	33.2	37.6	15.5
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-14 14	22.9	25.6	11.1	32.4	36.3	15.8
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-14 15	25.2	28	8.6	30.6	34	10.5
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-14 16	25.5	28.3	11.2	28.2	31.3	12.7
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-14 17	20.4	22.9	8.7	33.9	38.1	14.5
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-14 18	21	24.2	7.96	36.3	42	13.7
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-14 19	19.5	22.5	7.03	37.3	43	13.5
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-14 20	18.3	20.3	6.81	35	38.8	13.2
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-14 21	19.4	22	6.84	36.2	41.1	12.8
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-14 22	21.1	23.7	7.73	36.2	41.1	13.3
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-14 23	17.9	20.7	6.88	35.4	41.1	14
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-15 00	22.9	26.6	7.98	34.3	40	11.9
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-15 01	23.8	26.8	5.31	37.3	42.2	8.13
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-15 02	19.8	22.5	5.68	36.7	41.7	10.8

万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-15 03	19.2	22.2	4.09	37.9	43.9	7.97
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-15 04	20.9	23.9	7.12	34.3	39.3	11.7
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-15 05	21.2	24	7.93	36.5	41.5	13.7
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-15 06	22.1	25.5	6.13	36.4	42.1	9.77
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-15 07	16.4	19	5.82	34.8	40.1	13.1
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-15 08	13.7	15.2	5.75	30.8	34.2	13.1
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-15 09	6.78	7.96	3.16	34.3	40.1	15.9
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-15 10	18.8	22.7	9.18	36.7	44.3	17.9
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-15 11	22	26.1	8.81	33.8	40.3	13.6
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-15 12	18.6	20.8	7.11	28.8	32.1	11
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-15 13	16	18	7.72	31.8	35.8	15.2
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-15 14	13	14.1	6.57	33.2	36.2	16.8
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-15 15	19.3	21.3	9.32	33.3	37	15.8
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-15 16	13.5	14.9	5.95	33.9	37.4	15.1
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-15 17	21.4	23.9	9.49	36.7	41	16.3
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-15 18	24.4	27.2	11.1	36	40	16.4
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-15 19	19.7	21.8	7.96	37.2	41.3	15
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-15 20	22.4	25.1	8.52	37.4	42	14.3
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-15 21	24.1	26.8	8.66	35.5	39.6	12.7

万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-15 22	22.1	24.8	7.96	35.6	40.2	12.8
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-15 23	19.9	22.6	7.25	34.6	39.2	12.6
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-16 00	21.5	25	7.41	35.6	41.3	12.3
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-16 01	22.8	26.5	7.98	36.2	41.9	12.6
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-16 02	18.6	21.5	7.17	37	42.8	14.2
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-16 03	17.5	20.6	7.44	37.3	44	15.9
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-16 04	17.9	21.3	7.56	36.2	43.1	15.3
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-16 05	17.1	20.4	7.13	34.8	41.6	14.4
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-16 06	24.7	29.8	10.8	35.8	43	15.7
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-16 07	17.9	21.2	6.88	36.2	43.2	14.1
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-16 08	20.8	23.4	7.83	34	38.3	12.7
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-16 09	22.1	24.5	8.97	32.6	36.3	13.2
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-16 10	20.8	23.6	8.98	36.1	41.1	15.6
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-16 11	24	27.9	11.1	36.7	42.7	17
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-16 12	22.6	26.2	10.4	33.6	39	15.5
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-16 13	23.6	27.5	10.8	32	37.4	14.5
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-16 14	16.8	19.9	7.72	33.4	39.7	15.4
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-16 15	14.1	16.1	5.87	30.6	35	12.9
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-16 16	11.2	12.8	5.72	28.6	32.8	14.5

万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-16 17	10.4	11.8	5.28	28.8	32.5	14.6
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-16 18	15.6	17.8	7.24	29.6	33.7	13.8
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-16 19	19.7	21.8	9.15	29.6	32.9	13.7
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-16 20	21.2	23.7	9.75	30.4	33.9	13.9
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-16 21	20.7	23.7	8.88	30.1	34.6	12.9
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-16 22	19.9	22.8	8.36	29.6	34	12.5
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-16 23	21.4	24.2	9.81	33.9	38.3	15.6
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-17 00	21.4	24.5	7.99	35.4	40.7	13.4
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-17 01	21.9	25.6	8.4	36.3	42.5	13.9
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-17 02	20.6	24.2	6.95	37.6	44.3	12.7
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-17 03	19.6	22.9	7.08	36.7	43	13.3
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-17 04	17.7	20.9	5.68	35	41.5	11.3
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-17 05	12.8	15.2	4.11	36.5	43.3	11.5
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-17 06	18.9	22.6	5.32	37	44.3	10.5
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-17 07	21.4	25.2	6.59	34.2	40.3	10.5
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-17 08	24.2	28.2	8.08	33.2	38.6	11
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-17 09	23.6	27.3	9.43	30.2	35	12.2
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-17 10	21	24.1	10.1	32.2	36.9	15.5
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-17 11	22.4	25.4	12.5	34.8	39.6	19.3

万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-17 12	21.9	24.4	13	31.8	35.4	18.7
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-17 13	22.1	24.7	13.6	34	38.1	20.9
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-17 14	23.4	26.4	15.2	37.3	42.4	24.3
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-17 15	21.1	23.6	13.1	34.3	38.6	21.4
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-17 16	19.3	22.2	11.6	33.8	39	20.4
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-17 17	21.1	24.4	12.2	33.6	39.1	19.3
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-17 18	18.9	21.6	10.5	31.5	36.1	17.5
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-17 19	20.6	23.6	10.7	31.3	36	16.2
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-17 20	23.5	26.5	11.8	29.2	33.1	14.6
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-17 21	24.3	27.4	12	29.7	33.5	14.6
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-17 22	20.8	23.9	10.2	32.1	36.9	15.8
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-17 23	16.5	18.8	7.49	33.8	38.5	15.3
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-18 00	17.3	20.1	8.45	35.2	40.7	17
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-18 01	17.9	20.8	8.94	35.5	41.4	17.5
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-18 02	19.5	22.2	9.03	32.8	37.3	15
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-18 03	17.3	19.4	7.18	35.9	40.3	14.9
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-18 04	18	20.3	7.41	37.2	41.8	15.4
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-18 05	16.3	18.7	6.73	36.9	42.4	15.6
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-18 06	17.6	20.9	8.78	39.4	46.8	19.5

万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-18 07	15.9	18.9	7.3	36.7	43.8	17.1
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-18 08	18.3	21	8.09	36.8	42.4	16.9
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-18 09	18.4	20.8	9.59	34.2	38.6	17.8
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-18 10	22.4	26.1	12.1	32.9	38.3	17.7
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-18 11	25.2	28.7	13.6	34.1	38.9	18.4
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-18 12	23.8	26.7	13.9	33.6	37.8	19.3
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-18 13	24	27.2	14.6	36.5	41.4	22.2
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-18 14	19.6	22.3	12.3	38.7	44.1	24.2
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-18 15	18.2	20.8	11.3	38.9	44.5	24.2
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-18 16	16.9	19.4	10.9	35.2	40.4	22.8
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-18 17	19.6	22.3	11	31.2	35.6	17.7
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-18 18	22.2	25.7	11.8	33.8	39.4	17.9
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-18 19	20.9	23.9	11.9	33.4	38.4	19.1
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-18 20	22	25	11	32.3	36.5	16.1
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-18 21	23	26.4	10.7	33.7	38.6	15.8
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-18 22	22.3	25.6	9.46	34.6	39.8	14.7
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-18 23	25.4	29	9.07	33.9	38.7	12.1
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-19 00	21.8	25.2	7.84	33.6	38.9	12.1
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-19 01	22.6	25.5	8.98	31.9	36	12.7

万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-19 02	24.9	28.2	8.87	32.1	36.4	11.4
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-19 03	22.5	25.6	8.59	33.3	38.1	12.8
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-19 04	17.9	21.4	7.15	36.4	43.7	14.6
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-19 05	19.5	22.9	6.8	36.7	43.2	12.8
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-19 06	20.5	23.8	8.95	34.9	40.7	15.3
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-19 07	19.2	22.3	8.65	33.8	39.4	15.3
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-19 08	22	25.1	10.3	34	38.8	15.9
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-19 09	23.7	26.2	11.7	35.2	39	17.5
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-19 10	21	24	10.7	37.9	43.4	19.4
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-19 11	19.5	22.5	10.2	39.5	45.7	20.8
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-19 12	19.9	22.9	9.88	37.4	43.1	18.6
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-19 13	17.6	20	10	37.7	42.8	21.6
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-19 14	15.3	17.6	8.57	37.9	43.4	21.1
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-19 15	13.9	15.6	6.78	32.5	36.6	15.7
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-19 16	12.9	14.2	6.32	39.5	43.6	19.4
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-19 17	14	15.7	5.86	39.5	44.3	16.3
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-19 18	17	18.8	3.4	39.8	44.1	7.93
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-19 19	17.5	19.7	1.99	37.6	42.5	4.23
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-19 20	20.3	21.9	2.82	42.6	45.9	5.94



万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-19 21	20.5	22	0.235	42.6	45.7	0.464
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-19 22	19.7	21.4	0.205	44.4	48.2	0.434
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-19 23	18.5	20.2	0.194	44.3	48.4	0.456
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-20 00	21.2	23.7	0.17	35.1	39.4	0.325
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-20 01	15.3	17	0.085	36.1	40.3	0.202
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-20 02	17.5	19.5	1.06	44	49.1	2.12
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-20 03	20	22.1	0.639	39.2	43.3	0.997
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-20 04	19	20.5	0.106	35.9	38.8	0.201
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-20 05	20	21.8	0.112	34.4	37.5	0.193
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-20 06	21.1	23.1	0.124	39.9	43.7	0.234
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-20 07	21.2	22.7	0.181	38.8	41.5	0.331
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-20 08	23	24.5	0.448	39.5	42.1	0.767
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-20 09	22.8	23.8	1.21	35.3	36.8	1.98
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-20 10	22.2	23.2	3.93	38.8	40.5	6.67
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-20 11	17.5	18.4	4.15	35.9	37.9	8.57
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-20 12	20.8	21.7	4.89	44.2	46.2	10.5
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-20 13	27.9	29.3	7.16	38	39.9	9.83
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-20 14	18.1	18.7	5.09	37.4	38.8	10.4
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-20 15	7.35	7.86	2.14	38.8	41.5	11.3

万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-20 16	7.4	8.1	2.1	35.6	38.9	10.1
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-20 17	10.6	11.5	2.98	37.9	40.9	10.7
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-20 18	8.54	9.12	2.46	37.6	40.2	10.8
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-20 19	9.13	9.8	2.29	39.9	43	10.1
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-20 20	12.1	13.2	2.06	39.4	43	6.74
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-20 21	19.3	20.6	0.438	37.2	39.8	0.988
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-20 22	19.9	21.6	0.402	39.3	42.7	0.782
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-20 23	22.9	24.6	0.234	39.6	42.5	0.355
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-21 00	22.4	24.5	0.124	42	46.1	0.232
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-21 01	20.4	22.6	0.111	42.1	46.7	0.229
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-21 02	22.4	25	0.335	40.8	45.6	0.644
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-21 03	19.8	22.4	0.109	38.9	44.1	0.215
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-21 04	19.6	22.2	0.107	36.3	41.2	0.197
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-21 05	18.8	20.8	0.256	37.3	41.4	0.411
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-21 06	21.8	23.7	0.12	39.8	43.5	0.22
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-21 07	19.1	21.4	0.178	41.6	46.5	0.383
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-21 08	21.1	22.8	0.117	38.5	41.6	0.213
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-21 09	14.3	15.6	0.604	38.3	41.8	1.69
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-21 10	16.7	17.8	1.41	38.7	41.2	3.32

万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-21 11	14.2	15.2	2.48	35.6	38.2	6.76
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-21 12	18.3	20.1	2.16	34.8	38.2	4.1
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-21 13	20.4	21.9	4.28	37.5	40.3	8
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-21 14	19.8	21.2	4.84	35	37.4	8.41
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-21 15	19.7	21.4	15.2	36.2	39.2	24.3
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-21 16	29.9	70.1	15.2	35.5	156	24.3
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-21 17	20.9	22.6	3.78	33.2	36	6.02
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-21 18	21.2	22.6	3.83	39.2	42	7.03
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-21 19	22.7	25	4.52	42.9	47.2	8.61
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-21 20	25	27.7	5.49	39.1	43.5	8.55
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-21 21	20.5	23	3.55	33.3	37.4	5.57
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-21 22	25.4	28.2	1.59	34	38	2.12
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-21 23	22.6	25	0.124	33.2	36.8	0.182
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-22 00	16.3	17.6	0.089	40.4	43.9	0.221
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-22 01	15.8	17.6	0.184	40.7	45.4	0.487
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-22 02	22.9	25.2	0.126	35.3	38.9	0.195
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-22 03	17.7	19.6	0.57	37.5	41.8	0.927
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-22 04	21.5	24.4	0.269	33.5	37.9	0.426
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-22 05	20.5	23	3.73	35.6	40	6.62

万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-22 06	13.4	15.3	2.46	36.1	40.6	4.15
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-22 07	16	18.1	1.66	37	41.6	2.6
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-22 08	22	24.8	2.24	33.3	37.6	3.16
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-22 09	21.2	23.7	0.405	32.4	36.3	0.812
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-22 10	20.4	22.3	0.319	32.4	35.4	0.456
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-22 11	19.5	21.7	0.268	33.5	37.4	0.481
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-22 12	18.5	20.3	1.95	38.7	42.5	4.27
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-22 13	19.1	22	2.34	36.1	41.4	4.33
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-22 14	20	23.3	1.58	32.9	38.4	2.67
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-22 15	23.7	26	0.448	29.9	33	0.566
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-22 16	21.3	23.5	1.78	31.2	34.6	2.38
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-22 17	18.2	20.3	0.742	33.2	37.2	1.31
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-22 18	19	21.7	0.659	33.7	38.4	1.3
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-22 19	18.3	20.3	0.391	33.9	37.7	0.752
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-22 20	13.4	15.1	0.073	36.8	41.5	0.201
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-22 21	18.1	20.6	0.099	36.5	41.6	0.199
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-22 22	18.9	21.9	1.32	37	42.6	2.52
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-22 23	17.5	19.7	1.16	36.3	40.9	2.42
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-23 00	18.8	21.3	4.3	34.6	39.4	7.92

万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-23 01	21	23.1	4.14	36.5	40.3	7.18
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-23 02	20.8	22.7	4.49	39.2	42.9	8.45
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-23 03	20.4	22.5	4.81	40.6	44.8	9.56
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-23 04	19.6	22.5	4.67	36.7	42.2	8.71
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-23 05	18.8	21.3	1.11	38	43	2.26
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-23 06	17.3	20.1	2.26	36.1	42.1	4.39
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-23 07	17.1	19.3	0.489	38.1	43	1.26
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-23 08	18.1	20.2	4.13	40.6	45.4	9.13
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-23 09	15.9	18.2	3.81	37.1	42.2	8.73
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-23 10	9.67	11	1.3	36.5	41.3	3.85
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-23 11	16.9	18.9	2.29	35.2	39.6	4.26
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-23 12	15.6	17.9	0.66	31.6	36.2	1.62
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-23 13	9.72	11.1	2.35	34.5	39.4	8.34
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-23 14	17.2	19.3	4.06	32	35.9	7.54
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-23 15	20	22	2.34	33	36.4	4.24
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-23 16	14.3	16.1	2	33.6	37.8	3.89
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-23 17	15	16.8	3.21	35.2	39.6	7.64
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-23 18	15.7	17.9	0.087	36.1	41	0.199
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-23 19	16.1	18.2	0.09	34.6	39.5	0.194

万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-23 20	17.2	19.2	2.66	34.3	38.3	4.85
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-23 21	9.68	11.3	0.854	33.8	39.8	4.8
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-23 22	8.21	9.44	1.6	34.2	39.9	7.36
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-23 23	17.4	20.6	3.85	33.4	39.5	7.36
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-24 00	18.5	21.8	2.47	33	38.9	4.38
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-24 01	20.3	24	4.82	32	37.9	7.59
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-24 02	21.9	25.6	5.13	31.8	37.2	7.44
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-24 03	22.2	25.4	5.38	36.9	42.2	8.92
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-24 04	24.4	28.2	5.87	35.8	41.6	8.63
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-24 05	22.1	25.7	5.31	35.8	41.8	8.62
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-24 06	21.7	24.8	1.5	33.2	38	2.42
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-24 07	20.6	24.4	0.81	32.5	38.6	1.16
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-24 08	24.1	27.6	0.399	33.3	38.2	0.559
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-24 09	23.4	27	3.81	34.2	39.5	5.47
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-24 10	18.9	21.5	4.27	36.2	41.3	8.15
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-24 11	21.1	23.3	0.716	37	40.9	1.1
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-24 12	17.5	19.7	1.14	37.2	42	2.27
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-24 13	23.7	26.9	0.137	38.7	44.2	0.223
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-24 14	16.5	18.6	0.095	32.6	36.9	0.187

万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-24 15	21	23.8	0.199	34.4	39.2	0.29
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-24 16	21.6	25.1	0.193	30.7	35.8	0.269
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-24 17	26.1	29.2	0.202	31.5	35.3	0.254
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-24 18	18.3	21.1	0.172	30.7	35.4	0.284
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-24 19	21	23.9	0.367	27.9	31.7	0.484
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-24 20	18.1	21	4.04	27.2	31.6	6.07
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-24 21	22.5	25	4.99	26.8	29.7	5.92
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-24 22	20.7	23.1	3.79	28	31.3	5.1
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-24 23	21.5	23.6	0.212	34.1	37.8	0.329
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-25 00	20.4	23.4	4.11	31.7	36.3	6.45
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-25 01	19.2	21.4	4.06	30	33.6	6.16
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-25 02	14	15.5	1.9	32.8	36.4	4.92
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-25 03	15.7	17.7	3.08	37.4	42.2	6.95
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-25 04	16.5	19	3.09	35.4	40.7	6.3
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-25 05	16	18.4	2.93	36	41.4	6.26
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-25 06	19.7	22.5	2.43	37	42.2	4.53
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-25 07	21	23.8	2.64	35.3	40	4.23
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-25 08	21.9	24.3	3.27	34.7	38.5	5.23
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-25 09	23.3	25.1	2.91	40.8	43.9	5.15

万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-25 10	18.2	20.1	2.37	37.4	41.5	3.89
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-25 11	21.2	23.5	3.39	36.7	41.3	5.66
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-25 12	23.1	26.4	5.15	36.7	42.2	8.57
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-25 13	22.5	26.5	6.25	35.3	41.6	9.75
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-25 14	18.1	19.9	5.45	34.4	38.3	10.4
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-25 15	16	17.4	3.56	38.5	41.9	8.68
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-25 16	22.7	24.6	1.51	33.9	37.6	2.37
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-25 17	15.8	18.3	3.12	34.8	40.2	7
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-25 18	17.5	20	2.47	30.4	34.9	4.06
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-25 19	12.3	13.6	0.634	32.8	36.3	2.1
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-25 20	14	16	0.582	34.2	39.1	1.37
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-25 21	17.1	18.9	0.105	29.9	33.1	0.184
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-25 22	17.6	19.6	0.108	31.9	35.7	0.195
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-25 23	17.2	19	0.101	30.6	34	0.18
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-26 00	22.1	24.3	0.134	31.3	34.7	0.19
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-26 01	19.2	21.1	0.117	35	38.4	0.212
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-26 02	17.7	19.4	1.31	38.8	43	3.96
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-26 03	24.9	28	5.73	36.5	41	8.39
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-26 04	20.1	23	2.42	34.1	39	4.45



万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-26 05	22.8	26	3.68	35.5	40.5	5.89
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-26 06	22.4	25.1	2.02	34.7	39	3.22
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-26 07	23.4	26.1	2.7	35.5	39.7	4.39
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-26 08	24.2	27	5.3	35.8	40	7.83
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-26 09	22.4	24.5	3.53	37.3	40.7	4.78
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-26 10	18.8	20.6	0.328	40.1	44.2	0.76
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-26 11	18.2	20.4	0.32	38.1	42.7	0.727
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-26 12	18.9	21.2	0.796	37	41.7	1.51
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-26 13	19.3	21.9	0.959	36.9	41.7	2.05
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-26 14	23.2	25.5	2.35	36.7	40.3	3.69
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-26 15	25.7	28	4.78	39	42.6	7.28
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-26 16	23.4	27	2.46	34	39.1	3.43
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-26 17	18.4	21.4	0.114	33.8	39.2	0.209
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-26 18	20.4	23.1	0.128	37.8	42.6	0.237
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-26 19	17.4	19.9	0.978	36.8	42	3.49
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-26 20	11.5	13.6	1.51	32.5	40.4	4.7
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-26 21	26.6	30.5	6.05	33.7	38.7	7.64
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-26 22	21.2	23.8	5.14	38.7	43.5	9.41
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-26 23	16.4	19.1	2.6	35.9	41.8	5.86

万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-27 00	8.94	10.6	1.83	33.4	39.7	6.09
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-27 01	13.1	15.2	2.96	33.2	38.7	7.51
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-27 02	15.9	18.6	0.773	34.9	40.6	3.25
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-27 03	17.2	19.9	4.28	33.7	38.9	8.35
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-27 04	16	18.5	4.04	33.5	38.6	8.44
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-27 05	16.8	18.9	4.22	33.5	37.9	8.45
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-27 06	17.1	19.6	3.81	33.7	38.8	6.68
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-27 07	16.6	18.7	1.41	34.1	38.7	2.31
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-27 08	10.7	12	2.67	38.1	42.7	9.58
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-27 09	12.4	13.6	3.08	40.8	44.6	10.1
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-27 10	16.2	17.9	0.654	40.1	44.4	2.47
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-27 11	13.7	15.3	0.084	41.1	46	0.251
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-27 12	15.2	17	0.881	40.5	45.2	2.42
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-27 13	9.73	10.9	2.31	37.1	41.5	8.59
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-27 14	15.7	17.7	4.02	40.3	45.4	10.3
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-27 15	16.5	18.6	0.787	36.4	41.3	1.7
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-27 16	14.2	16.2	0.35	36.9	42.2	0.942
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-27 17	14.7	17	0.09	37.8	43.9	0.231
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-27 18	20.8	24.2	0.171	34.8	40.5	0.295

万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-27 19	13	14.8	0.079	37.4	42.9	0.226
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-27 20	15.4	17.7	2.54	37.4	43.2	6.14
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-27 21	9.18	10.6	0.888	36.6	42.3	3.35
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-27 22	11.9	13.4	1.52	38.8	43.7	4.5
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-27 23	21.4	24.4	2.05	38.3	43.5	2.48
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-28 00	14.4	16.5	1.76	36.4	41.6	4.25
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-28 01	14.5	16.1	3.12	28.4	31.5	5.93
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-28 02	11.8	13.2	2.84	34	38	8.03
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-28 03	17.9	20.1	2.7	36.5	41.1	6.01
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-28 04	14.6	16.7	3.6	35.2	40.3	8.76
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-28 05	15.1	17.2	3.87	34.8	39.5	8.93
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-28 06	15.3	17.2	3.89	35	39.4	8.88
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-28 07	13.3	15	3.42	34.3	38.8	8.82
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-28 08	23	25.4	3.7	36.7	40.7	4.66
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-28 09	14.5	16.2	0.952	38.9	43.4	3.84
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-28 10	14.9	16.7	3.06	36.4	40.8	7.26
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-28 11	15.1	16.8	3.86	36.7	40.5	9.34
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-28 12	8.71	9.62	2.21	38.4	42.5	9.75
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-28 13	8.53	9.32	2.18	38	41.5	9.69

万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-28 14	8.7	9.41	1.26	39.5	42.8	5.96
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-28 15	13.9	15.7	1.88	41.2	46.3	5.55
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-28 16	15.9	18.1	2.75	37	42.2	6.38
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-28 17	15.6	17.8	2.78	33.4	38.2	5.95
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-28 18	13.6	15.4	2.45	34.5	39.2	6.22
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-28 19	10	11.6	1.06	34.7	39.9	3.6
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-28 20	9.94	11.7	0.081	34.4	40.5	0.3
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-28 21	11.8	13.7	1.71	32	37.6	3.55
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-28 22	5.67	6.46	0.485	33.6	38.3	3.78
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-28 23	13.1	14.7	0.087	34.8	39.3	0.223
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-29 00	20.5	23.3	1.2	38.1	43.5	2.31
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-29 01	13.8	15.8	0.842	39.7	45.4	1.54
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-29 02	11.5	12.9	1.71	39.4	44.2	4.62
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-29 03	20.1	23.3	2.95	37.1	42.8	5.19
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-29 04	7.1	8.23	0.833	34.7	40.2	4.6
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-29 05	16.6	19.6	2.94	35.6	42.2	6.2
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-29 06	16.2	19.6	2.88	35	42.2	5.94
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-29 07	9.98	12	1.33	34.6	41.6	4.79
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-29 08	14.9	18.1	1.83	32.9	39.8	4.32

万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-29 09	5.46	6.54	0.888	34.7	41.6	5.45
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-29 10	3.02	3.53	0.545	35.1	40.9	6.34
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-29 11	13.9	16.5	1.46	38.1	45	4.23
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-29 12	21.3	25.4	2.75	32.9	39.3	4.48
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-29 13	12	14.6	0.554	34.3	41.5	1.47
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-29 14	17.2	20.2	1.48	33.4	39.2	3.2
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-29 15	19.6	23	2.46	33.1	38.8	4.55
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-29 16	12.6	15.3	2.34	33.8	41.2	6.39
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-29 17	13.6	16.1	1.51	30.7	36.8	4.68
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-29 18	16.8	20.4	3.01	31.8	38.6	5.67
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-29 19	16.8	20.1	2.08	32.4	38.9	4.3
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-29 20	15.7	18	2.68	34.6	39.8	5.95
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-29 21	21.6	24.8	2.98	33	37.9	4.91
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-29 22	21.5	24.9	3.28	39.2	45.2	6.27
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-29 23	7.21	8.38	1.12	33.8	39.3	5.51
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-30 00	19.7	23.3	3.46	36.1	42.7	6.39
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-30 01	7.13	8.46	1.31	34.8	41.2	6.37
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-30 02	16.7	20.1	2.99	32.4	38.9	5.73
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-30 03	15	17.9	2.83	34.8	41.7	6.55

万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-30 04	13.6	16.3	2.45	30.3	36.3	5.48
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-30 05	21	24.3	3.58	37.2	43.2	6.18
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-30 06	20.4	24.5	3.99	33.3	39.9	6.5
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-30 07	13.4	16.1	1.73	37.5	44.7	5.04
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-30 08	12.8	15	2.25	33.1	39	5.96
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-30 09	14.2	17.2	2.68	32.4	39.1	6.07
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-30 10	9.25	10.9	0.966	33.1	39.1	4.75
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-30 11	19.7	22.7	2.47	34	39.4	3.78
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-30 12	8.17	9.55	1.1	32.1	38	4.75
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-30 13	16.7	19.8	0.762	33.6	40	2.56
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-30 14	6.03	7.13	0.611	36.4	43	2.4
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-30 15	24.6	28.4	3.05	33.1	38.3	4.11
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-30 16	21.1	24.7	0.421	33.4	39.2	0.594
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-30 17	9.52	10.9	0.055	36.2	41.4	0.218
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-30 18	9.97	11.2	0.48	33.9	38.6	2.15
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-30 19	2.47	2.89	0.106	36.4	42.5	1.69
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-30 20	0.679	1.9	0.008	10.8	13	0.061
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-30 21	3.98	4.46	0.829	7.51	8.44	1.56
万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-30 22	17.6	20.2	3.11	36.8	42.2	6.46

万达热电	万达热电1#1-3号 75t/h循环流化床锅炉	2022-06-30 23	13.2	16.1	2.13	36.4	44.4	5.91
		平均值	18.4	21.1	4.39	34.8	40	7.75
		最大值	30.2	70.1	15.4	44.4	156	24.3
		最小值	0.679	1.9	0.008	7.51	8.44	0.061
		累计值			3164			5577

## 三锅炉\_小时数据

烟尘			氧气 (%)	烟气温 度 (°C)	流量 (m3)	烟气湿 度 (% RH)
实测浓 度 (mg/M 3)	折算浓 度 (mg/M 3)	排放量 (kg)				
0.845	0.923	0.006	7.28	52.8	5601	14.6
0.804	0.877	0.006	7.26	52.9	5587	14.8
0.823	0.948	0.006	7.95	53.3	5570	14.9
0.847	1.05	0.006	8.9	52.7	5598	14.6
0.84	1.02	0.006	8.62	52.5	5616	14.4
0.847	0.973	0.006	7.92	52.9	5588	14.7
0.845	0.955	0.006	7.74	53	5583	14.8
0.848	0.976	0.006	7.97	52.8	5607	14.5
0.879	0.982	0.006	7.56	52.8	5611	14.4
0.88	1.03	0.006	8.2	52.7	5619	14.3
0.917	1.11	0.006	8.59	52.4	5646	14
0.875	1.07	0.006	8.74	52.2	5675	13.6
1.15	1.35	0.007	8.25	52.1	5697	13.3
1.23	1.44	0.007	8.19	52.4	5675	13.5
0.908	1.08	0.006	8.33	52.5	5685	13.4
0.704	0.822	0.006	8.14	52.6	5688	13.3



0.683	0.811	0.006	8.35	52.7	5674	13.5
0.675	0.789	0.006	8.16	52.9	5645	13.9
0.66	0.764	0.006	8.05	53.1	5617	14.2
0.653	0.751	0.006	7.94	53.2	5595	14.6
0.647	0.746	0.006	7.97	53.2	5582	14.7
0.644	0.76	0.006	8.27	53	5575	14.9
0.714	0.865	0.006	8.61	53.1	5585	14.7
0.658	0.807	0.006	8.75	52.6	5611	14.5
0.691	0.853	0.006	8.84	52.5	5612	14.4
0.652	0.8	0.006	8.77	52.2	5640	14.1
0.667	0.828	0.006	8.92	52.2	5640	14.1
0.655	0.792	0.006	8.59	52	5653	14
0.67	0.851	0.006	9.18	52	5654	14
0.68	0.836	0.006	8.78	52.1	5652	14
0.664	0.794	0.006	8.43	52	5652	14
0.657	0.762	0.006	8.06	52.4	5635	14.1
0.67	0.765	0.006	7.85	53	5613	14.3
0.7	0.772	0.006	7.38	53.3	5590	14.6
0.67	0.764	0.006	7.83	52.4	5660	13.8

0.685	0.773	0.006	7.69	52.5	5663	13.7
1.07	1.23	0.007	7.86	52.8	5661	13.7
0.732	0.833	0.006	7.81	53	5649	13.8
0.728	0.818	0.006	7.64	53	5641	13.9
0.731	0.811	0.006	7.47	53.2	5642	13.9
0.765	0.875	0.006	7.86	53.3	5632	14
0.724	0.839	0.006	8.05	52.8	5648	13.9
0.718	0.846	0.006	8.27	52.6	5649	13.9
0.712	0.853	0.006	8.47	52.6	5644	14
0.699	0.811	0.006	8.06	52.6	5635	14.1
0.703	0.812	0.006	8.01	53	5603	14.5
0.693	0.822	0.006	8.34	52.9	5604	14.5
0.706	0.824	0.006	8.13	53.4	5580	14.7
0.714	0.828	0.006	8.06	53.6	5547	15.2
0.722	0.85	0.006	8.25	53.8	5548	15.1
0.711	0.843	0.006	8.34	53.4	5554	15.1
0.715	0.841	0.006	8.24	53.8	5527	15.4
0.703	0.823	0.006	8.18	53.8	5528	15.4
0.706	0.852	0.006	8.55	53.4	5559	15

0.719	0.858	0.006	8.41	53.4	5569	14.9
0.734	0.883	0.006	8.54	53.2	5585	14.7
0.727	0.85	0.006	8.15	52.8	5622	14.3
0.723	0.87	0.006	8.53	53	5617	14.3
0.741	0.902	0.006	8.67	53	5632	14.1
0.724	0.874	0.006	8.57	53.2	5622	14.2
0.734	0.857	0.006	8.15	53.4	5637	13.9
0.754	0.889	0.006	8.27	53.1	5667	13.5
0.938	1.1	0.007	8.13	53.1	5683	13.2
0.66	0.773	0.006	8.18	52.6	5716	12.9
0.787	0.916	0.006	8.11	53.7	5653	13.6
0.675	0.797	0.006	8.28	54	5610	14.1
0.694	0.805	0.006	8.08	54.1	5563	14.8
0.671	0.784	0.006	8.14	54.2	5545	15.1
0.666	0.761	0.006	7.86	54.7	5499	15.6
0.669	0.778	0.006	8.07	54.5	5502	15.7
0.65	0.77	0.006	8.33	53.9	5535	15.3
0.634	0.751	0.006	8.33	53.9	5540	15.2
0.617	0.739	0.006	8.46	53.7	5550	15.1

0.615	0.73	0.006	8.36	53.6	5544	15.2
0.602	0.722	0.006	8.48	53.8	5525	15.4
0.609	0.729	0.006	8.47	54	5517	15.5
0.606	0.725	0.006	8.45	53.9	5515	15.6
0.606	0.733	0.006	8.59	53.7	5526	15.5
0.607	0.729	0.006	8.49	53.5	5545	15.2
0.614	0.727	0.006	8.33	54	5516	15.6
0.607	0.68	0.006	7.6	54.5	5495	15.7
0.624	0.692	0.006	7.47	54.9	5459	16.2
0.63	0.703	0.006	7.56	54.9	5477	15.9
0.642	0.71	0.006	7.44	54.9	5488	15.7
0.678	0.764	0.006	7.67	55	5506	15.4
0.679	0.756	0.006	7.53	55.3	5463	16
0.778	0.88	0.006	7.71	55.4	5475	15.8
0.694	0.786	0.006	7.76	55.6	5454	16.1
0.653	0.731	0.006	7.58	54.9	5482	15.9
0.656	0.744	0.006	7.77	55.2	5463	16
0.666	0.763	0.006	7.91	55.6	5432	16.4
0.692	0.784	0.006	7.74	55.4	5444	16.3

0.667	0.757	0.006	7.79	55	5432	16.6
0.644	0.742	0.006	7.96	54.2	5502	15.7
0.709	0.918	0.006	9.41	53.6	5552	15.1
0.803	1.04	0.006	9.41	53	5568	15
0.663	0.845	0.006	9.22	53.2	5566	15
0.664	0.792	0.006	8.43	52.9	5594	14.7
0.666	0.775	0.006	8.11	53.7	5548	15.2
0.661	0.768	0.006	8.08	54	5518	15.6
0.649	0.768	0.006	8.32	53.6	5535	15.4
0.65	0.772	0.006	8.38	53.7	5518	15.6
0.667	0.802	0.006	8.52	53.6	5547	15.2
0.678	0.806	0.006	8.38	53.2	5567	15
0.786	0.905	0.006	7.97	53.8	5544	15.2
0.806	0.921	0.006	7.85	54	5535	15.3
0.797	0.932	0.006	8.18	54.3	5525	15.4
0.806	0.935	0.006	8.06	54.2	5531	15.3
0.995	1.15	0.007	8.02	53.6	5551	15.2
0.861	1.02	0.006	8.28	53	5596	14.6
0.867	1.02	0.006	8.22	52.7	5663	13.7

0.875	1.05	0.006	8.51	52.1	5723	13
0.876	1.03	0.006	8.27	52.1	5730	12.9
0.843	0.997	0.006	8.31	52.6	5705	13.1
0.818	0.947	0.006	8.04	52.9	5654	13.8
0.797	0.904	0.006	7.77	53.1	5612	14.3
0.794	0.91	0.006	7.91	52.8	5612	14.4
0.812	0.919	0.006	7.75	52.9	5589	14.8
0.796	0.934	0.006	8.2	52.7	5606	14.5
0.808	0.964	0.006	8.42	52.5	5630	14.2
0.794	0.941	0.006	8.34	52.5	5631	14.2
0.779	0.902	0.006	8.03	52.5	5632	14.2
0.798	0.922	0.006	8.02	52.8	5602	14.6
0.799	0.934	0.006	8.17	52.5	5619	14.4
0.786	0.94	0.006	8.46	52.2	5640	14.2
0.792	0.957	0.006	8.59	51.7	5674	13.8
0.776	0.912	0.006	8.23	51.8	5660	13.9
0.743	0.867	0.006	8.14	51.9	5661	13.9
0.76	0.881	0.006	8.06	52.6	5615	14.4
0.77	0.894	0.006	8.08	52.5	5615	14.4

0.771	0.884	0.006	7.91	52.5	5632	14.2
0.771	0.894	0.006	8.06	52.6	5627	14.3
0.827	0.981	0.006	8.35	52.2	5675	13.6
1.31	1.56	0.007	8.33	51.9	5681	13.6
0.813	0.987	0.006	8.63	51.8	5678	13.7
0.725	0.866	0.006	8.43	51.9	5684	13.6
0.726	0.879	0.006	8.6	51.8	5705	13.3
0.714	0.866	0.006	8.62	51.6	5707	13.3
0.72	0.864	0.006	8.48	51.9	5699	13.3
0.709	0.841	0.006	8.36	52	5680	13.6
0.706	0.845	0.006	8.46	52	5653	14
0.691	0.816	0.006	8.28	51.9	5652	14
0.694	0.822	0.006	8.33	52.2	5614	14.6
0.701	0.852	0.006	8.66	52.1	5630	14.3
0.681	0.821	0.006	8.55	51.9	5653	14
0.686	0.822	0.006	8.47	52.1	5642	14.1
0.697	0.821	0.006	8.25	52.3	5623	14.4
0.694	0.817	0.006	8.25	52.5	5617	14.4
0.707	0.825	0.006	8.15	52.4	5623	14.4

0.749	0.883	0.006	8.28	52.3	5636	14.2
0.76	0.899	0.006	8.32	52.4	5604	14.6
0.777	0.916	0.006	8.28	52.7	5606	14.5
0.763	0.9	0.006	8.27	52.6	5610	14.5
0.715	0.838	0.006	8.19	52.3	5640	14.1
0.699	0.816	0.006	8.14	52.4	5625	14.3
0.725	0.856	0.006	8.28	52.6	5640	14
0.738	0.862	0.006	8.15	53.1	5620	14.2
0.806	0.922	0.006	7.85	53.1	5617	14.3
0.889	1.03	0.007	8.06	52.6	5648	13.9
0.685	0.802	0.006	8.17	52.1	5656	13.9
0.677	0.777	0.099	7.93	43.5	174994	13.3
0.688	0.818	0.147	8.37	52	213078	14
0.686	0.805	0.152	8.21	51.9	221529	14
0.682	0.8	0.158	8.21	51.8	231479	13.8
0.683	0.77	0.164	7.68	52	239688	14
0.676	0.766	0.161	7.75	52	237842	14.1
0.692	0.795	0.169	7.93	52	244184	14.1
0.693	0.804	0.166	8.06	51.8	243437	14



0.695	0.808	0.213	8.08	52	305470	14.3
0.678	0.799	0.254	8.27	51.7	376347	14
0.687	0.814	0.276	8.35	51.5	401893	14.1
0.683	0.81	0.251	8.34	51.8	368552	14
0.695	0.824	0.303	8.36	52.1	435726	14.3
0.694	0.817	0.264	8.24	52.4	379809	14.4
0.688	0.807	0.256	8.21	52.4	371975	14.7
0.684	0.801	0.279	8.2	52.4	407518	14.5
0.702	0.823	0.315	8.2	52.4	448428	14.6
0.711	0.84	0.338	8.3	52.6	475707	14.6
0.704	0.827	0.347	8.23	52.6	493040	14.4
0.714	0.798	0.352	7.56	52.6	492935	14.5
0.732	0.834	0.376	7.81	52.5	513671	14.4
0.731	0.835	0.385	7.87	52.3	526754	14.2
0.745	0.846	0.385	7.78	52.8	517594	14.3
0.767	0.866	0.412	7.71	52.7	536301	14.4
0.741	0.823	0.398	7.49	52.8	537278	14.5
0.746	0.833	0.362	7.55	52.9	486124	14.4
0.735	0.859	0.314	8.16	52.8	425762	14.5

0.709	0.8	0.25	7.7	52.8	353440	15
0.696	0.785	0.243	7.7	53.1	349763	15
0.697	0.799	0.145	7.92	52.9	207638	14.9
0.696	0.81	0.06	8.1	52.9	84398	14.9
0.698	0.818	0.061	8.21	52.7	85390	14.7
0.698	0.828	0.131	8.36	52.5	187711	14.8
0.695	0.792	0.15	7.84	52.6	215672	14.8
0.694	0.791	0.205	7.83	52.6	295326	14.7
0.696	0.806	0.222	8.04	52.5	318675	14.5
0.709	0.83	0.21	8.18	52.5	296075	14.5
0.711	0.824	0.196	8.06	52.6	274827	14.7
0.686	0.783	0.211	7.86	52.3	309010	14.6
0.695	0.789	0.258	7.8	52.9	370090	14.8
0.707	0.796	0.316	7.67	53.1	446456	15
0.713	0.792	0.288	7.48	53.3	404324	15.1
0.724	0.804	0.281	7.5	53.5	388056	15.1
0.93	1.03	0.425	7.44	53.6	450156	15.2
1.17	1.31	0.571	7.6	53.9	486687	15
0.818	0.906	0.401	7.46	54	490420	15.2

0.808	0.895	0.426	7.47	53.9	527190	14.9
0.821	0.927	0.452	7.7	54	550379	15
0.819	0.917	0.457	7.6	54.2	558329	15.5
0.815	0.924	0.448	7.76	54.1	549455	15.6
0.776	0.905	0.426	8.13	53.5	548752	15.6
0.76	0.862	0.366	7.76	53.6	480725	15.5
0.761	0.847	0.335	7.53	53.7	440844	15.5
0.76	0.843	0.284	7.48	53.5	373829	15.6
0.77	0.866	0.296	7.66	53.7	384429	15.5
0.764	0.85	0.303	7.52	53.3	396907	15.1
0.787	0.855	0.319	7.17	53.6	419518	15.2
0.8	0.861	0.341	7.05	53.9	425349	15.4
0.796	0.872	0.354	7.29	53.5	444566	15.1
0.806	0.901	0.337	7.58	53.5	426048	15.1
0.798	0.872	0.344	7.27	53.4	432258	14.9
0.775	0.862	0.34	7.51	53.4	447331	15.1
0.79	0.872	0.278	7.41	53.8	351686	15.3
0.842	0.922	0.139	7.31	53.9	174026	15.7
0.761	0.854	0.155	7.62	53.9	203091	15.8

0.736	0.83	0.32	7.7	53.1	435962	15.4
0.821	0.926	0.379	7.71	53.2	461494	15.4
0.92	1.04	0.454	7.75	53.2	494268	15.1
0.783	0.896	0.412	7.89	53	527555	14.9
0.792	0.904	0.445	7.86	53.2	562368	15
0.794	0.906	0.415	7.86	53	522432	14.7
0.793	0.902	0.404	7.8	53.2	510499	14.8
0.796	0.899	0.409	7.71	53.6	512482	15.1
0.799	0.913	0.435	7.87	53.6	544422	15.1
0.779	0.896	0.381	7.96	53.1	489264	15.1
0.763	0.86	0.349	7.69	53.1	456868	14.9
0.778	0.88	0.352	7.73	53.4	452411	15.2
0.77	0.891	0.372	8.03	53.3	483870	15.4
0.764	0.903	0.348	8.3	52.8	465039	15.1
0.788	0.926	0.358	8.23	53.5	454310	15.2
0.734	0.843	0.258	7.94	53.3	357161	15.3
0.726	0.83	0.257	7.87	53.3	353676	15.1
0.713	0.805	0.251	7.71	53.2	351991	15.1
0.716	0.797	0.261	7.51	53.6	364653	15.5

0.718	0.831	0.281	8.03	53	391916	15.3
0.719	0.836	0.271	8.09	53.2	377150	15.2
0.73	0.841	0.296	7.99	53.3	406254	15.2
0.719	0.833	0.32	8.04	52.9	445106	15
0.721	0.823	0.348	7.86	53.1	483193	15
0.718	0.788	0.347	7.32	53.7	483684	15.1
0.745	0.839	0.391	7.68	53.6	524881	15.2
0.743	0.829	0.411	7.55	53.6	553382	14.9
0.772	0.872	0.43	7.72	53.8	557047	15.1
0.781	0.865	0.449	7.45	53.8	574980	15
0.793	0.888	0.444	7.61	53.9	559385	14.8
0.776	0.878	0.466	7.74	53.4	600506	14.7
0.764	0.877	0.472	7.91	53.6	617520	14.6
0.751	0.856	0.429	7.82	53.5	572015	14.9
0.743	0.849	0.402	7.87	53.5	541211	15.1
0.745	0.836	0.427	7.63	53.8	573792	15.4
0.737	0.822	0.412	7.55	53.8	559222	15.5
0.719	0.822	0.364	7.87	53.5	507246	15.5
0.726	0.851	0.371	8.21	53.2	511921	15.5

0.737	0.85	0.352	7.97	53.5	478094	15.2
0.736	0.864	0.363	8.22	53	493604	14.9
0.718	0.828	0.354	7.99	52.9	494593	14.7
0.725	0.828	0.346	7.86	53	477215	14.8
0.729	0.838	0.34	7.95	53.1	466909	14.9
0.723	0.844	0.331	8.15	52.5	457508	14.5
0.742	0.854	0.32	7.97	53.1	431529	14.7
0.739	0.846	0.371	7.9	53.2	502740	14.9
0.736	0.85	0.369	8.01	53.1	500824	14.9
0.748	0.856	0.401	7.88	53.1	536001	14.6
0.786	0.875	0.387	7.52	53.7	493344	15.1
0.779	0.875	0.412	7.65	53.8	529592	15
0.778	0.862	0.423	7.45	53.8	543351	14.8
0.797	0.905	0.442	7.79	53.6	554585	14.6
0.832	0.932	0.494	7.62	53.4	584808	15
0.726	0.808	0.39	7.5	52.7	537000	14.9
0.738	0.817	0.363	7.45	52.8	493274	14.9
0.726	0.827	0.403	7.81	52.9	555136	14.9
0.704	0.823	0.38	8.16	52.2	540788	14.5

0.702	0.841	0.342	8.49	52.2	488592	14.4
0.702	0.811	0.323	8.01	52.7	459997	14.8
0.699	0.796	0.326	7.81	53	466035	14.9
0.7	0.781	0.323	7.55	53.3	460963	15.3
0.699	0.803	0.328	7.95	52.8	468746	15
0.709	0.805	0.296	7.78	52.8	417887	14.8
0.705	0.807	0.284	7.89	52.7	402648	14.8
0.682	0.765	0.29	7.62	52.2	424925	14.4
0.702	0.798	0.307	7.79	52.7	436735	14.6
0.705	0.799	0.284	7.76	53	402177	14.8
0.685	0.778	0.283	7.79	52.8	413209	14.8
0.684	0.778	0.329	7.8	53.1	480595	14.9
0.846	1	0.414	8.33	53.2	490876	15.1
0.776	0.918	0.429	8.31	52.3	553479	14.4
0.731	0.849	0.33	8.07	52.4	451628	14.6
0.717	0.797	0.326	7.48	52.9	454419	14.9
0.728	0.82	0.354	7.67	53.1	486583	14.8
0.725	0.825	0.382	7.82	52.5	528583	14.5
0.739	0.85	0.392	7.96	52.7	530718	14.6

0.724	0.825	0.453	7.83	52.7	628330	14.4
0.678	0.792	0.414	8.16	51.5	609537	13.9
0.687	0.78	0.292	7.79	52.2	425198	14.3
0.703	0.816	0.334	8.05	52.3	473741	14.2
0.691	0.796	0.301	7.97	52.2	435702	14.4
0.678	0.791	0.242	8.14	51.7	356796	14.1
0.689	0.775	0.229	7.67	52.4	333265	14.4
0.699	0.792	0.243	7.74	52.5	348042	14.4
0.677	0.767	0.2	7.77	51.9	295822	14.4
0.678	0.774	0.178	7.86	51.8	264225	14.1
0.7	0.796	0.259	7.82	52	370353	14.2
0.709	0.812	0.223	7.9	51.7	318294	14
0.767	0.869	0.234	7.76	52.2	305112	14.2
0.777	0.881	0.216	7.76	52.3	278834	14.3
0.805	0.909	0.188	7.72	52.3	234810	14.3
0.777	0.897	0.036	8	51.9	44330	14.2
0.776	0.891	0.1	7.94	51.9	129937	14.2
0.788	0.926	0.204	8.24	51.9	260269	14.2
0.896	1.03	0.371	7.95	51.7	415914	14



0.904	1.02	0.386	7.68	52.2	428078	14.1
0.787	0.872	0.337	7.46	52.2	429151	14
0.778	0.864	0.322	7.49	52.2	413521	14.1
0.792	0.874	0.38	7.41	52.4	480616	14
0.857	0.946	0.397	7.41	53	463622	14.4
0.932	1.05	0.457	7.72	52.3	484672	14.1
0.968	1.08	0.484	7.58	52.6	495740	14.2
1.21	1.35	0.415	7.49	53.1	444578	14.6
0.805	0.891	0.362	7.44	52.8	451429	14.2
0.77	0.864	0.336	7.63	52.9	434382	14.7
0.78	0.904	0.294	8.04	52.8	375589	14.7
0.765	0.88	0.278	7.96	52.7	363471	14.6
0.73	0.809	0.274	7.46	52.7	377389	14.8
0.736	0.838	0.269	7.81	52.9	365178	14.8
0.738	0.835	0.275	7.72	52.8	372960	14.9
0.755	0.877	0.295	8.06	52.4	390825	14.7
0.723	0.842	0.251	8.11	52	347487	14.4
0.72	0.813	0.158	7.73	52.2	219519	14.1
0.721	0.82	0.212	7.8	52.4	295987	14.4

0.733	0.848	0.154	8.03	52.4	209464	14.4
0.736	0.842	0.25	7.9	52.2	340071	14.5
0.758	0.862	0.289	7.8	52.4	381124	14.4
0.748	0.866	0.201	8.03	52.2	270547	14.5
0.769	0.886	0.291	7.98	52.5	376603	14.6
0.801	0.89	0.338	7.5	52.8	425689	14.6
0.818	0.955	0.378	8.14	52.6	462674	14.4
0.784	0.947	0.38	8.57	52	485732	14.1
0.775	0.92	0.319	8.35	52.2	413373	14
0.765	0.853	0.292	7.54	52.1	382143	13.8
0.894	1	0.431	7.67	52.3	479960	13.6
1.11	1.2	0.561	7.24	52.2	507074	13.5
0.845	0.937	0.401	7.46	52.8	476125	14.2
0.822	0.906	0.366	7.38	53	445192	14.4
0.781	0.871	0.347	7.55	52.9	444623	14.4
0.756	0.84	0.345	7.5	52.6	456016	14.4
0.742	0.824	0.3	7.47	52.7	403596	14.6
0.749	0.841	0.286	7.63	52.7	381219	14.7
0.752	0.838	0.268	7.54	52.9	357080	14.8

0.731	0.823	0.264	7.67	52.5	360914	14.6
0.708	0.802	0.263	7.76	52.2	372708	14.5
0.722	0.837	0.253	8.05	52.8	350387	14.9
0.736	0.854	0.258	8.06	52.9	349881	14.9
0.734	0.848	0.282	8.03	52.6	384002	14.9
0.717	0.843	0.305	8.24	51.6	426002	14.5
0.735	0.876	0.31	8.41	52	422772	14.3
0.745	0.888	0.309	8.42	51.9	415550	14.2
0.762	0.913	0.333	8.47	51.8	437498	14
0.77	0.916	0.298	8.4	52.1	387551	14.2
0.766	0.862	0.286	7.66	52.4	372347	14.1
0.752	0.838	0.308	7.53	52.4	409705	14.4
0.758	0.862	0.327	7.82	52.8	431794	14.6
0.756	0.88	0.349	8.11	52.2	462528	14.2
0.752	0.871	0.347	8.04	52.1	461568	14
0.759	0.885	0.356	8.13	52.1	470190	13.8
0.759	0.897	0.35	8.3	52.1	460525	13.7
0.782	0.895	0.342	7.89	52.4	438145	14.1
0.77	0.881	0.39	7.89	52.4	507589	13.9

0.777	0.877	0.394	7.72	52.5	506316	14.2
0.774	0.882	0.361	7.84	52.7	466089	14.1
0.758	0.843	0.352	7.5	52.9	464838	14.5
0.752	0.838	0.344	7.54	53.1	457572	14.7
0.744	0.854	0.32	7.94	53	430091	14.7
0.739	0.846	0.31	7.9	52.7	420443	14.5
0.73	0.824	0.336	7.7	52.6	460338	14.7
0.683	0.783	0.261	7.92	52	384598	14.6
0.696	0.814	0.266	8.17	52.4	383122	14.6
0.706	0.83	0.239	8.24	52.7	343520	14.6
0.717	0.84	0.26	8.19	52.9	362608	14.8
0.72	0.854	0.23	8.35	52.5	320598	14.5
0.712	0.845	0.226	8.36	52.1	319574	14.5
0.725	0.868	0.205	8.47	52.6	283062	14.6
0.736	0.868	0.226	8.28	52.9	307976	14.8
0.72	0.838	0.238	8.11	53.1	337950	14.7
0.722	0.835	0.291	8.03	53.3	403353	14.9
0.719	0.825	0.345	7.93	53.1	480908	14.4
0.724	0.822	0.408	7.78	53.2	563930	14

0.764	0.85	0.451	7.52	53.8	588744	14.1
0.99	1.11	0.609	7.59	54	614274	14
1.07	1.21	0.686	7.75	54.3	649452	14.6
0.828	0.932	0.517	7.66	54.4	624694	15
0.806	0.928	0.494	7.94	54.2	614134	15
0.793	0.919	0.455	8.05	54.1	573956	14.9
0.766	0.875	0.425	7.86	53.3	554866	14.8
0.761	0.876	0.395	7.95	53.2	518859	14.7
0.746	0.844	0.374	7.72	53	502001	14.7
0.761	0.857	0.382	7.68	53.3	501550	14.8
0.754	0.868	0.371	7.96	53.2	492130	15
0.751	0.856	0.341	7.84	53.1	454906	14.7
0.767	0.887	0.377	8.04	52.5	491361	14.6
0.736	0.855	0.365	8.09	52.2	496775	14.6
0.723	0.822	0.334	7.8	52.4	462543	14.4
0.728	0.817	0.307	7.63	52.1	421452	14.3
0.724	0.814	0.301	7.66	51.9	415082	14.2
0.723	0.831	0.307	7.94	51.8	423885	14
0.724	0.861	0.361	8.38	51.2	498408	13.6

0.72	0.857	0.334	8.41	50.6	465518	13.4
0.721	0.83	0.324	7.94	51.1	449907	13.2
0.785	0.891	0.408	7.72	51.6	517388	13.3
1.06	1.24	0.572	8.09	52.1	538934	13.6
0.747	0.852	0.404	7.84	52.7	540051	13.7
0.779	0.877	0.449	7.67	53.2	576525	13.7
0.817	0.925	0.496	7.74	53.6	607350	13.8
0.908	1.03	0.568	7.83	53.7	626841	14
0.792	0.905	0.493	7.88	53.5	622537	13.9
0.738	0.849	0.479	7.95	53.3	648348	14.2
0.737	0.84	0.417	7.83	53.8	565590	14.8
0.726	0.844	0.385	8.09	53.3	531094	14.7
0.724	0.831	0.414	7.92	53.1	571381	14.8
0.713	0.807	0.355	7.75	53.2	498572	14.8
0.708	0.812	0.331	7.93	53.2	467424	14.9
0.69	0.792	0.292	7.93	52.8	424473	14.7
0.712	0.812	0.254	7.84	53.4	356325	15
0.708	0.818	0.255	8.01	53.1	361243	14.8
0.688	0.776	0.273	7.7	53	397428	14.8

0.699	0.791	0.248	7.75	53.2	356055	15
0.708	0.808	0.272	7.86	53	384732	14.9
0.705	0.845	0.282	8.49	52.6	399972	14.7
0.714	0.84	0.254	8.26	52.9	355594	14.7
0.741	0.864	0.324	8.13	52.8	437291	14.6
0.734	0.851	0.33	8.07	52.7	450604	14.8
0.738	0.843	0.346	7.86	53.2	467707	14.6
0.802	0.887	0.404	7.43	53.6	503980	14.9
0.863	0.988	0.45	7.9	53.7	521818	14.8
0.883	1.02	0.472	8.03	53.6	535306	14.6
0.875	1.01	0.433	7.95	53.6	494864	14.3
0.829	0.94	0.472	7.78	52.9	571803	13.7
0.825	0.944	0.46	7.89	53.3	558711	13.7
0.822	0.92	0.399	7.57	53.9	484456	14
0.786	0.87	0.383	7.41	54	488786	14.6
0.787	0.884	0.324	7.64	54.8	411878	15.4
0.778	0.864	0.152	7.46	54.6	196174	15.6
0.763	0.862	0.086	7.72	54.6	111095	15.8
0.732	0.788	0.104	7.06	54.4	142132	16.1

0.71	0.761	0.01	7.01	54.5	10905	16
0.72	0.783	0.009	7.2	54.3	9767	15.7
0.712	0.778	0.009	7.27	53.9	10555	15.9
0.722	0.808	0.009	7.6	53.5	9469	15.7
0.73	0.814	0.006	7.54	53.7	5673	15.4
0.711	0.793	0.038	7.54	53.4	51011	15
0.705	0.78	0.026	7.44	53.3	34729	14.9
0.688	0.745	0.006	7.14	53	5592	14.7
0.678	0.738	0.006	7.23	52.9	5608	14.6
0.696	0.762	0.006	7.29	53	5875	14.6
0.7	0.75	0.008	6.99	53.2	8425	14.6
0.71	0.755	0.015	6.9	53.4	19763	14.6
0.689	0.72	0.035	6.65	53.6	48977	14.7
0.698	0.729	0.122	6.65	54	174694	14.9
0.752	0.795	0.181	6.8	54.4	239259	15
0.733	0.765	0.173	6.63	54.9	236635	15
0.74	0.777	0.191	6.72	55	257253	15
0.787	0.816	0.219	6.54	55.2	279461	15.2
0.772	0.827	0.227	7	55	298236	14.9



0.753	0.824	0.215	7.29	54.7	284639	14.3
0.748	0.807	0.208	7.09	54.7	279046	14.4
0.748	0.798	0.214	6.94	54.2	286041	14.4
0.714	0.769	0.178	7.05	53.6	250895	14.5
0.696	0.76	0.116	7.27	53.6	168834	14.6
0.706	0.755	0.019	6.98	54.4	25655	15.2
0.71	0.77	0.015	7.17	54.5	19074	15.3
0.693	0.744	0.009	7.02	54.3	9412	15.2
0.721	0.791	0.006	7.32	54.3	5527	15.3
0.729	0.809	0.006	7.48	54.1	5537	15.2
0.716	0.801	0.013	7.58	53.8	15735	14.9
0.722	0.82	0.006	7.79	54	5542	15.2
0.723	0.822	0.006	7.8	54.1	5535	15.2
0.686	0.761	0.009	7.47	53.4	10746	14.8
0.687	0.752	0.006	7.27	54.3	5523	15.4
0.696	0.778	0.009	7.57	54	9568	15.1
0.669	0.723	0.006	7.11	54.4	5528	15.3
0.664	0.724	0.03	7.25	54.5	43542	15.2
0.67	0.712	0.059	6.88	54.8	85894	15.2

0.638	0.684	0.119	7.02	53.5	188106	14.1
0.671	0.737	0.081	7.35	54.6	118416	14.2
0.688	0.739	0.147	7.05	54.6	214216	14.2
0.697	0.747	0.168	6.99	55	245487	15.1
0.692	0.746	0.686	7.06	54.8	247387	14.9
0.701	2.52	0.686	6.04	55.1	287416	15.1
0.702	0.76	0.126	7.12	55.2	207261	15.6
0.707	0.756	0.127	6.97	55.2	178848	15.7
0.729	0.804	0.146	7.37	55	199464	15.7
0.729	0.812	0.159	7.51	54.6	217302	15.4
0.697	0.784	0.117	7.66	54.1	166681	15.2
0.673	0.75	0.043	7.54	54	63078	15
0.68	0.753	0.006	7.44	55.2	5483	15.8
0.684	0.744	0.006	7.2	55.3	5476	15.8
0.68	0.759	0.01	7.56	54.2	11980	15.7
0.674	0.743	0.006	7.37	54.6	5498	15.7
0.684	0.761	0.021	7.51	54.8	27051	15.9
0.697	0.79	0.011	7.76	54.6	13074	15.7
0.691	0.776	0.13	7.64	54.4	188296	15.5

0.714	0.806	0.093	7.7	55.2	128058	15.9
0.699	0.787	0.056	7.66	55	77885	15.8
0.69	0.78	0.07	7.71	54.5	99803	15.6
0.664	0.745	0.018	7.62	54.9	24996	15.6
0.682	0.745	0.011	7.26	55.8	13002	16
0.691	0.771	0.012	7.56	55.8	14125	15.6
1.04	1.14	0.119	7.31	55.1	108619	15.5
1.01	1.17	0.131	7.93	55.4	126852	15.4
0.783	0.918	0.065	8.13	55	80456	15.4
0.721	0.794	0.015	7.37	55.2	18545	15.3
0.73	0.808	0.058	7.45	55.5	78780	15.5
0.732	0.821	0.032	7.61	55.5	43313	15.8
0.723	0.825	0.028	7.85	54.9	37855	15.8
0.722	0.802	0.018	7.5	54.8	22620	16
0.726	0.817	0.006	7.67	55.1	5457	16.2
0.731	0.833	0.006	7.82	55.1	5468	16
0.726	0.836	0.053	7.98	54.8	72240	15.8
0.696	0.784	0.051	7.67	54.6	70827	15.8
0.687	0.781	0.157	7.81	53.9	228917	15.2

0.692	0.765	0.138	7.42	54.7	199563	15.8
0.691	0.756	0.149	7.29	54.8	214412	16
0.7	0.772	0.164	7.41	54.5	235441	15.8
0.719	0.827	0.17	7.94	54.2	237400	15.9
0.718	0.813	0.047	7.75	54.2	63129	15.7
0.706	0.823	0.089	8.13	54	124684	15.6
0.697	0.787	0.025	7.7	53.4	32213	15.1
0.704	0.788	0.158	7.59	53.9	224609	15.5
0.718	0.817	0.168	7.81	53.9	234720	15.3
0.73	0.826	0.082	7.74	54	111641	15.3
0.721	0.811	0.089	7.64	54	122423	15.5
0.731	0.841	0.039	7.94	53.5	48207	15
1.32	1.52	0.322	7.88	53.5	241795	14.6
0.704	0.79	0.166	7.62	53.1	235676	14.4
0.718	0.792	0.091	7.39	53.6	125705	14.4
0.723	0.812	0.089	7.65	53.7	122007	14.5
0.718	0.808	0.156	7.65	53.5	217535	14.3
0.711	0.808	0.006	7.79	53.2	5609	14.3
0.695	0.792	0.006	7.83	52.9	5604	14.5

0.697	0.778	0.101	7.54	53.6	143757	14.7
0.712	0.836	0.103	8.23	53.6	141543	14.8
0.738	0.86	0.159	8.12	53.4	214702	14.7
0.696	0.823	0.153	8.31	52.6	220694	14.5
0.679	0.801	0.093	8.28	52	135630	13.8
0.692	0.819	0.164	8.32	52.7	237278	14.2
0.673	0.787	0.16	8.18	52.8	238383	14.2
0.67	0.766	0.162	7.89	52.8	241992	14.2
0.667	0.775	0.161	8.07	52.7	241160	14.3
0.66	0.77	0.159	8.13	52.3	240928	14
0.663	0.757	0.05	7.87	52.5	75499	14
0.701	0.83	0.027	8.33	53.2	36475	14.3
0.707	0.811	0.014	7.93	53.3	16887	14.6
0.716	0.825	0.117	7.97	53.5	163089	14.7
0.7	0.799	0.158	7.82	53.6	225274	14.8
0.664	0.734	0.023	7.42	53.5	31221	14.4
0.691	0.78	0.044	7.69	51.8	61376	12.8
0.728	0.832	0.006	7.83	52.7	5859	13.3
0.733	0.827	0.006	7.69	53.1	5728	13.3

0.727	0.828	0.008	7.8	53.4	8582	13.4
0.704	0.821	0.008	8.12	53.3	8983	13.4
0.696	0.78	0.007	7.6	53.2	7963	13.2
0.684	0.791	0.008	8.01	53.2	8956	13.3
0.688	0.783	0.014	7.82	53.1	17449	13.7
0.679	0.789	0.151	8.08	53	223216	13.9
0.664	0.736	0.147	7.46	53.1	221277	14.2
0.649	0.726	0.119	7.56	52.7	182092	13.8
0.645	0.714	0.008	7.41	52.6	9757	13.8
0.654	0.75	0.133	7.91	52.6	203404	13.8
0.65	0.727	0.137	7.59	52.7	210997	13.9
0.667	0.74	0.106	7.48	52.8	158044	14
0.66	0.744	0.122	7.68	52.4	183458	13.7
0.663	0.761	0.117	7.92	52.4	176172	13.7
0.676	0.776	0.12	7.94	52.7	177041	14
0.676	0.771	0.084	7.85	52.8	122425	14
0.664	0.752	0.083	7.77	52.8	122724	13.9
0.647	0.716	0.097	7.45	53	148780	14
0.659	0.709	0.084	7.07	53.4	126703	14.1

0.653	0.723	0.07	7.43	54	106716	14.2
0.664	0.744	0.102	7.55	54.7	153982	14.4
0.83	0.956	0.203	7.93	54.5	234474	14.2
1.11	1.29	0.289	8.27	54.1	277910	13.8
0.722	0.807	0.221	7.55	54.6	306062	14
0.719	0.78	0.16	7.18	55.1	222998	14.4
0.712	0.786	0.05	7.37	55.3	68400	14.9
0.709	0.823	0.139	8.05	54.2	195483	14.9
0.662	0.759	0.089	7.9	53.5	134110	14.5
0.655	0.726	0.042	7.45	54	63215	14.6
0.664	0.756	0.027	7.82	53.8	38860	14.4
0.66	0.729	0.006	7.4	54.2	6140	14.5
0.66	0.738	0.006	7.57	54.3	6127	14.7
0.658	0.733	0.006	7.52	54.2	6099	15.1
0.658	0.729	0.006	7.44	54.4	6091	15.1
0.666	0.73	0.006	7.32	54.7	6066	15.4
0.67	0.743	0.07	7.44	54.7	101574	15.5
0.673	0.757	0.155	7.66	54.3	230053	15.5
0.664	0.759	0.087	7.89	53.7	130462	14.9

0.659	0.754	0.11	7.87	54	167323	14.9
0.652	0.731	0.06	7.62	54.3	90682	15
0.657	0.736	0.08	7.59	54.2	120172	14.8
0.65	0.726	0.145	7.57	54.2	222655	14.9
0.661	0.721	0.087	7.26	54.8	131339	14.8
0.676	0.743	0.014	7.34	55.1	18216	15
0.689	0.77	0.015	7.57	55.1	18741	15.2
0.787	0.883	0.038	7.69	54.7	40871	14.8
0.872	0.98	0.067	7.72	54.2	55189	15.2
0.714	0.783	0.073	7.32	54.5	102419	14.8
0.724	0.79	0.135	7.24	54.6	185979	14.7
0.716	0.823	0.074	7.95	53.5	100379	15
0.65	0.754	0.006	8.05	52.3	6172	14.6
0.631	0.711	0.006	7.69	51.4	6269	13.4
0.637	0.727	0.064	7.84	51.8	98020	13.5
0.634	0.769	0.084	8.56	52.6	132554	14.2
0.632	0.726	0.143	7.91	52.7	224990	14.3
0.633	0.713	0.154	7.64	53.2	243304	14.5
0.641	0.747	0.11	8.11	52.9	170161	14.4



0.648	0.769	0.119	8.33	52.7	182324	14.2
0.652	0.758	0.148	8.08	52.6	225851	14.4
0.651	0.757	0.059	8.09	52.6	89722	14.3
0.656	0.757	0.162	8	52.6	247827	14.2
0.656	0.756	0.166	7.99	52.6	252201	14.1
0.648	0.731	0.163	7.69	52.7	252037	14
0.647	0.746	0.132	8	53	202481	14.5
0.653	0.74	0.045	7.77	53.1	66151	14.4
0.678	0.758	0.17	7.58	53.2	250899	14.6
0.709	0.776	0.176	7.28	53.6	248747	14.5
0.706	0.781	0.047	7.44	53.9	63858	14.8
0.699	0.782	0.006	7.58	53.9	6103	15.1
0.746	0.835	0.042	7.58	54.2	54328	14.9
0.734	0.821	0.168	7.57	53.9	228371	15
0.743	0.836	0.19	7.66	54	255634	15.4
0.738	0.836	0.036	7.75	54	44122	15.2
0.719	0.824	0.018	7.89	53.7	23842	15.2
0.751	0.872	0.006	8.08	53.8	6110	15
0.742	0.865	0.008	8.13	53.5	8393	15.6

0.71	0.813	0.006	7.9	54	6033	16
0.712	0.823	0.117	8.01	53.9	163726	15.1
0.704	0.815	0.064	8.04	53.5	91081	15.6
0.692	0.779	0.086	7.68	53.6	123341	14.9
0.695	0.79	0.051	7.8	53.4	71595	15.3
0.714	0.817	0.091	7.89	53.8	124879	15.2
0.703	0.78	0.147	7.48	54	208554	15.4
0.709	0.793	0.168	7.59	53.5	236495	15.1
0.669	0.754	0.111	7.68	53.1	164220	14.9
0.676	0.775	0.169	7.92	52.7	249181	14.7
0.673	0.765	0.173	7.79	52.8	256799	14.7
0.678	0.762	0.175	7.65	52.8	257920	14.6
0.689	0.777	0.177	7.71	53.1	256952	14.7
0.682	0.757	0.088	7.48	53.2	127986	14.8
0.696	0.776	0.07	7.55	53.3	98262	14.6
0.694	0.777	0.137	7.6	53.4	196429	14.7
0.703	0.775	0.179	7.39	53.6	254615	14.7
0.721	0.797	0.183	7.43	53.8	254074	15
0.718	0.785	0.183	7.28	53.8	255218	14.9

0.699	0.757	0.106	7.14	53.1	185029	14.4
1.48	1.68	0.215	7.66	53.1	142537	14.8
0.69	0.787	0.121	7.85	52.8	175703	14.6
0.675	0.772	0.122	7.88	52	181015	14
0.688	0.782	0.124	7.79	52	180584	13.9
0.699	0.804	0.072	7.95	52.9	101161	14.5
0.715	0.84	0.008	8.23	53.2	8540	14.6
0.724	0.849	0.083	8.19	53.3	115258	15
0.697	0.793	0.079	7.82	53.3	112147	15
0.687	0.776	0.007	7.7	53.3	6418	15.6
0.686	0.784	0.044	7.84	53	61952	14.9
0.689	0.787	0.029	7.87	52.8	39624	14.7
0.696	0.782	0.084	7.65	53	118688	14.8
0.693	0.8	0.097	8.02	52.7	138975	14.5
0.69	0.799	0.092	8.05	52.7	131761	14.4
0.7	0.83	0.122	8.34	52.7	174395	14.6
0.709	0.855	0.121	8.55	52.7	170398	14.4
0.712	0.857	0.099	8.53	52.6	138147	14.2
0.689	0.831	0.091	8.53	52.5	132213	14

0.703	0.842	0.11	8.48	52.7	156904	14
0.673	0.786	0.122	8.15	51.9	180795	13.5
0.668	0.787	0.08	8.22	52.1	117576	13.4
0.679	0.811	0.093	8.44	52.4	135866	13.8
0.679	0.82	0.031	8.58	52.6	43022	13.7
0.682	0.801	0.064	8.21	52.3	91621	13.5
0.693	0.812	0.094	8.19	52.6	134123	13.6
0.699	0.849	0.134	8.66	52.8	191874	14.1
0.694	0.83	0.104	8.44	52.9	149417	14.3
0.691	0.838	0.124	8.61	52.6	178549	14.1
0.69	0.828	0.09	8.49	52.7	132111	14.2
0.678	0.777	0.115	7.88	52.9	169511	14.3
0.686	0.788	0.103	7.95	53.6	149322	15
0.695	0.801	0.11	7.98	53.7	159102	14.7
0.697	0.809	0.113	8.08	54.1	161341	15.5
0.69	0.816	0.122	8.31	53.3	177070	15
0.723	0.855	0.132	8.31	53.5	182950	15
0.705	0.846	0.125	8.5	53.1	177799	14.6
0.704	0.841	0.132	8.43	53.3	188068	14.6

0.706	0.846	0.128	8.47	53.1	181157	14.8
0.718	0.834	0.123	8.07	52.4	171464	14.2
0.722	0.865	0.141	8.49	53.1	195353	14.6
0.694	0.827	0.093	8.41	53.4	132429	14.7
0.726	0.854	0.131	8.23	53.4	180422	14.6
0.697	0.839	0.13	8.54	53.1	187233	14.4
0.689	0.813	0.098	8.28	53.3	142192	14.1
0.696	0.805	0.077	8.02	53.2	108453	14.2
0.93	1.09	0.128	8.33	53.2	149180	13.9
0.85	1.02	0.057	8.4	53.2	73359	14
0.734	0.866	0.052	8.27	52.8	69668	13.8
0.735	0.847	0.092	8.02	53.4	165832	14.4
0.735	0.862	0.014	8.2	53.4	17837	14.4
0.751	0.859	0.006	7.88	54	6027	14.8
0.754	0.859	0.049	7.81	54.2	62766	15.2
0.796	0.93	0.037	8.16	54.3	45163	15.2
0.722	8.16	0.322	16.5	53.2	117142	15.4
0.71	0.78	0.144	18.6	53	203205	15
0.703	0.807	0.124	7.91	52.8	175627	14.6

0.712	0.867	0.116	8.68	53.2	162307	14.7
0.735	0.854	0.17	7.91	53.2	223134	14.6
1.48	8.16	0.686	18.6	55.8	649452	16.6
0.602	0.68	0.006	6.04	43.5	5432	12.8
		122			160656757	